

Data Centre Site Certification

This certification is awarded to

TIA942 rating

Electrical: Rating 3 2N

Architectural: Rating 3

Mechanical: Rating N+1

Telecommunications: Rating 1

OMAN DATA PARK

Zone 2, 7th Floor. KOM4

Knowledge Oasis Muscat

PO Box 789, PC 112 Ruwi

Sultanate of Oman

The site audited by us on 10-12-19 complies with the Rating 3 requirements of ANSI-TIA942:2017 for Electrical and Architectural requirements and N+1 for the mechanical (cooling) systems and Rating 1 for Telecommunications. This certificate should be read in conjunction with Capitoline report ODP181219 18/12/19 where any observations pertinent to this certification may be recorded. Capitoline Ltd makes no warranty of the suitability of this site beyond those defined in our report.

Authorised By



Matt Flowerday CEng MIET MBA BSc(Hons) DCDC RCDD RTPM

Issue date: 18th December 2019

Valid till: 17th December 2021

CAPITOLINE

